

CERTIFICATE

Issued to:
Applicant:
Bluesun Solar Co., Ltd.
Building No.7, 1499 Zhenxing Road, Shushan District
230031 Hefei City Anhui, China

Product : Crystalline Silicon PV Modules
Trade name(s) : Solarhome
Type(s)/model(s) : BSMxxxM-60HPH, BSMxxxM-72HPH, BSMxxxM10-54HPH,
BSMxxxM10-60HPH, BSMxxxM10-66HPH, BSMxxxM10-72HPH and
BSMxxxM10-78HPH

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) IEC TS 62804-1:2015
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 6059481
- the licensee is registered with the number 43597


DEKRA hereby grants the right to use the DEKRA Seal certification mark.

The DEKRA Seal certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the DEKRA Seal certification agreement.

This certificate is issued on 28 January 2022 and expires at the latest on 18 January 2027.

Certificate number: 31-122305

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Crystalline Silicon PV Modules
Trade name(s)	: Solarhome
Type(s)/model(s)	: BSMxxxM-60HPH, BSMxxxM-72HPH, BSMxxxM10-54HPH, BSMxxxM10-60HPH, BSMxxxM10-66HPH, BSMxxxM10-72HPH and BSMxxxM10-78HPH
Maximum System Voltage	: 1500 V
Design	: PV module with mono c-Si cells
Test Condition	: $\pm 1500V$, 85% RH, 85 °C, Stress method A with 96+96h

Product data – type BSMxxxM10-54HPH

Description : xxx=395-410, in steps of 5, 108 cells

Product data – type BSMxxxM10-60HPH

Description : xxx=445-460, in steps of 5, 120 cells

Product data – type BSMxxxM10-66HPH

Description : xxx=485-505, in steps of 5, 132 cells

Product data – type BSMxxxM10-72HPH

Description : xxx=530-550, in steps of 5, 144 cells

Product data – type BSMxxxM10-78HPH

Description : xxx=575-595, in steps of 5, 156 cells

Product data – type BSMxxxM-60HPH

Description : xxx=360-380, in steps of 5, 120 cells

Product data – type BSMxxxM-72HPH

Description : xxx=435-455, in steps of 5, 144 cells

TESTS**Test requirements**

IEC TS 62804-1:2015

Test result

The test results are laid down in DEKRA test file 612385100.

Additional information

The list of components is laid down in test report 6107099H.50.

Conclusion

The examination proved that all requirements were met.

Factory locations

The factory locations are registered with the numbers 43597, 54772, 52702 and 56592.

Trade name(s): Solarhome stands for

Solarhome

Unique Identifier

